

MPCL/JARI/MOEF/2022-23/ 04

Dated: 29.12.2022

Scientist " C",
Ministry of Environment, Forest & Climate Change
Regional Office (North Central Zone)
25 Subash Road, Dehradun – 248001

Subject: - Information regarding Environmental safe guard by Malana Hydro Electric Project

Dear Sir,

With reference to subject cited matter, the information desired by you regarding environmental safeguards for our project are as under.

1. The six monthly progresses achieved under Compensatory Afforestation and CAT Plan during the FY 2022-23 up to 30.09.2022 for Malana-1 HEP is enclosed herewith as Annexure-1
2. We are continuing the facilities of Acupressure, free medicines & providing part time service of qualified allopathic doctor for the people of surrounding villages in addition to our employees.(Details of the patient and budget allocated is attached as Annexure-II along with the CSR & EHS expenditure of last year)
3. We are releasing the minimum 15% discharge in the river course .Online monitoring of the discharge and this six monthly compliance report can be seen on our web site www.malanapower.com
4. We have planted 1000 nos. sapling of deodar and other species of plants(Robinia, kosh) in this winter .
5. In addition to this we are disposing the solid waste generated in our housing complex through the Solid Waste Treatment Plant of at our sister- concern ADHEPL at Prini – Manali.(Detail mentioned in Annexuere III
6. Copy of previous consent to operate up to 31/03/2025 has been sent to your office earlier with our official letter no. MPCL/JARI/MOEF/2022-23/87 dated 28.06.2022
7. Noise pollution details , e-waste returns and water sample tests results are attached as annexure IV
8. Regarding the constitution of multi-disciplinary committee (to check the physical and financial progress of the CAT Plan , compensatory afforestation, and possibility to handing over the unused forest land along with Dumping sites) the matter had been again taken up with the local forest Deptt and is still pending at their end.
9. Soft copy of the above six monthly progress report will be uploaded on our web site www.malanapower.com simultaneously please.
This is for your kind information please.

Yours faithfully,

For & on Behalf of
Malana Power Co. Ltd



(Er T.K. Trehan)
VP (O&M)
Encls. – As above

Malana Power Company Limited

Site & Regd. Office :
Village Chowki, P. O. Jari, Tehsil Bhunter
Distt. Kullu - 175 105 , (H.P.), India
Tel. : +91-1902-276074 / 75
Fax : +91-1902-276351
Website : www.malanapower.com
GSTIN: 02AABCM1108R2ZM


Corporate Office :
Bhilwara Towers, A-12, Sector-1
Noida - 201 301 (NCR-Delhi), India
Tel. : +91-120-4390300 (EPABX)
Fax : +91-120-4277841
Website : www.lnjbhilwara.com
GSTIN: 09AABCM1108R1Z9

Corporate Identification Number: U40101HP1997PLC019959

No. CAMPA/2022-23/ 9516
Himachal Pradesh Forest Department.

Dated Shamshi, the 28/12/2022

From:- Deputy Conservator of Forest,
Parvati Forest Division Shamshi.

To:-  General Manager,
M/S Malana Power Company Limited (Malana-I HEP
Village Chowki, PO Jari, Tehsil Bhunter, Distt. Kullu, HP

Subject:- **Progress achieved under CAT PLAN Malana-I HEP .**

Sir,

Please find enclosed herewith Physical & Financial quarterly progress report for the quarter ending on 30.09.2022 under CAT PLAN of Malana-I hydro Electric Power Project for favour of kind information and further necessary action please.

Encls: As above.

Yours faithfully,


(Aishwarya Raj), IFS
Deputy Conservator of Forest,
Parvati Forest Division Shamshi.
G.Mail- dfoparvati@gmail.com.
Phone No. 01902-265041

Details of Patients at Acupressure Health Centre FY 2022-23				
Sr. No.	Months	Number of Patient (MPCL Employees)	Number of Patient (Villagers & Others)	Total Patients attended
1	April, 2021	24	60	84
2	May	24	65	89
3	June	30	47	77
4	July	29	76	105
5	August	37	76	113
6	September	25	51	76
7	October	25	40	65
8	November	33	73	106
9	December	10	79	89
	Total	237	578	815

MPCL Patients Detail FY 2022-23				
Sr. No.	Period	Patients		Total
		Villagers	Employees & family members	
1	April, 2021	118	108	226
2	May	68	183	251
3	June	56	172	228
4	July	85	219	304
5	August	89	126	215
6	September	104	120	224
7	October	119	117	236
8	November	113	169	282
9	December	115	135	250
	Total	867	1349	2216

H. C. Sharma

MALANA HYDRO ELECTRIC POWER PLANT					
CSR and EHS&S Budgetary Provision:					
Sr. No.	Financial Year	Particular	Budget (in Million)	Actual Expenditure (in Million)	
1	2022-23	SAFETY	1.62	0.77	
2		HEALTHCARE	2.63	1.61	
3		EDUCATION	8.00	4.49	
5		ENVIRONMENTAL SUSTAINABILITY AND ECOLOGICAL BALANCE	0.80	0.56	
7		RURAL DEVELOPMENT	1.40	0.76	
8		EMPOWERING WOMEN	0.90	0.68	
9		NGOs	0.95	0.52	
			TOTAL	14.68	8.62

H. S. An

Detail of Garbage sent to ADHEPL

S. No.	Date	Quantity	Total wt.	Trolley wt.	Net wt.(Kgs)	Remark
1	08-07-2022	1	2850	2600	250	
2	29-07-2022	1	3470	3040	430	
3	11-08-2022	1	3340	2960	380	
4	26-08-2022	1	3360	2960	400	
5	13-09-2022	1	3350	2980	370	
6	28-09-2022	1	3400	2990	410	
					2240	
1	19-10-2022	1	3470	3040	430	
2	02-11-2022	1	3440	2960	480	
3	16-11-2022	1	3420	3020	400	
4	30-11-2022	1	3520	2990	530	
5	16-12-2022	1	3560	2970	590	
6	29-12-2022	1	3420	2990	430	
					2860	
				G.Total (kgs)	5100	

Hedra



Annexure - 12



PROUD TO BE INDIAN
PRIVILEGED TO BE GLOBAL

MPCL/JARI/PCB/2022-23/133

Dated. 27/10/2022

Assistant Environment Engineer H.P. State ,
Pollution Control Board,
Regional Office ,Himuda Shopping Complex,
Hall No.-5, Kullu, Distt. Kullu (H.P.)

Subject :- Regarding submission of Quarterly return for generation or storage or treatment or Disposal of E-Waste

Dear Sir,

Enclosed herewith please find the quarterly (July 2022 – Sept. 2022) I e- waste return on form -3 in respect of Malana Hydro Electric Project for further needful at your end.

Thanking You.

Yours truly,

For and On Behalf of

Malana Power Company Ltd.

(Er. T.K.Trehan)

VP – (O & M)

Encls. :- a/a

Malana Power Company Limited

Site & Regd. Office :
Village Chowki, P. O. Jari, Tehsil Bhunter
Distt. Kullu - 175 105 , (H.P.), India
Tel. : +91-1902-276074 / 75
Fax : +91-1902-276351
Website : www.malanapower.com
GSTIN: 02AABCM1108R2ZM

Corporate Office :
Bhilwara Towers, A-12, Sector-1
Noida - 201 301 (NCR-Delhi), India
Tel. : +91-120-4390300 (EPABX)
Fax : +91-120-4277841
Website : www.lnjbhilwara.com
GSTIN: 09AABCM1108R1Z9

Corporate Identification Number: U40101HP1997PLC019959



Himachal Pradesh State Pollution Control Board

'Him Parivesh', Phase -III, New Shimla-171009, HP.

Form-3

Rule 4(5), 5(5),8(6),10(8),11(9),13(1) (xi) ,13(2)(v), 13(3)(vii)and 13(4)(v)
FORM FOR FILING ANNUAL RETURNS

QUANTITY IN METRIC TONNES(MT) AND NUMBERS

(i)	Name and address of the producer or manufacturer or refurbisher or dismantler or recycler	Malana Power Company Ltd. Vill. Dunkhra P.O.- Manikarn Distt. Kullu (H.P.)		
(ii)	Name of the authorized person and complete address with telephone and fax numbers and e-mail address	T.K.Trehan V.P. (O&M), Te. No. & Fax No. 01902276351 tk.trehan@lnjbhilwara.com		
(iii)	Total quantity of e-waste collected or channelized to recyclers or dismantlers for processing during the year for each category of electrical or electronic equipment listed in the schedule-I (Attached list) by PRODUCERS	NIL		
(iv)	Details of above	TYPE	QUANTITY	No.
	BULK CONSUMERS- Quantity of e-waste			
	REFURBISHERS: Quantity of e-waste			
	DISMANTLERS : I Quantity of e-waste processed (code wise) Ii Details of materials or components recovered and sold Iii Quantity of e-waste sent to recycler Iv 'Residual quantity of e-waste sent to treatment, Storage and Disposal Facility			
	RECYCLERS : I Quantity of e-waste processed (code wise) Ii Details of materials recovered and sold in the market Iii Quantity of e-waste sent to recycler Iv Detail of residual sent to treatment, Storage and Disposal Facility		NIL	
	Name and address of the destination with respect to 3(A)-3 (D)		N/A	

(T.K.Trehan)

Vice President
Malana Power Company Ltd.
Vill. Dhunkhra, P.O Jar Distt. Kullu (H.P.) 175105

Annexure - IV

MPCL NOISE LEVEL RECORD FROM JULY - 2022 TO DECEMBER- 2022

Sample Frequency (Monthly)	Ambient Noise Parameters as per standard	Ambient Noise Parameters in WBG/IFC UNIT as per location wise (Power House)					
		Month	d B	Control Room	Service Bay	Generator Floor	Turbine Floor
Jul-22	75 d B(A)		54.2	75.4	85.8	88.4	64.4
Aug-22	75 d B(A)		55.9	76.2	85.7	88.7	64.7
Sep-22	75 d B(A)		57.0	72.9	87.0	88.7	64.6
Oct-22	75 d B(A)		56.1	73.7	84.2	86.9	63.3
Nov-22	75 d B(A)		56.0	72.4	83.9	86.3	61.9
Dec-22	75 d B(A)		53.9	68.7	83.9	85.6	62.4



Pankaj Upadhyay
A.M.(Electrical)